

Technical parameters		
Parameter description		Value
1	Transformer type	MarkoEco2 800/15.75-0.42 AkAAo (Tier2)
2	Construction type	
	• Hermetically sealed	YES
	• With conservator	NO
3	Rated power (kVA)	800 kVA
4	Frequency (Hz)	50 Hz
5	Primary winding HV	
	• Rated voltage (V)	15750 V
	• Tappings	±3×2,5%
	• Winding material	Cooper (Cu)
	• Insulation level Um/AC/LI	17.5/38/95
6	Secondary winding LV	
	• Rated voltage (V)	420 V
	• Winding material	Cooper (Cu)
	• Insulation level Um/AC/LI	1.1/8/-
7	Vector group	Dyn 5
8	Standards	EN 60076, EN 50588-1, EN 50708-1
9	Cooling	ONAN
10	Installation	Outdoor / Indoor
11	Installation altitude	up to 1000 m a.s.l.
12	Ambient	-25 °C ... +40 °C
13	Rated temperature rise	
	• Oil	60 K
	• Winding	65 K
14	No load losses (W)	585 W
15	Load losses (W)	6000 W
16	Short circuit impedance (%)	6% (±10%)
17	Approximate dimensions	
	• Length (mm)	1600 mm
	• Width (mm)	1050 mm
	• Height (mm)	1800 mm
	• Wheel spacing (mm)	670 mm
18	Approximate weight	
	• Cooper (kg)	576 kg
	• Core (kg)	1000 kg
	• Tank (kg)	340 kg
	• Oil (kg)	500 kg
	• Total (kg)	3126 kg
19	Corrosion protection	Galvanizing plus final coating RAL 7033

Standard equipment required for grid operation

	Equipment item	pcs.	Additional description
1	Porcelain insulators HV side	3	
2	Porcelain insulators LV side	4	
3	Tap changer	1	+/- 3 x 2,5% (hand operated)
4	Nameplates	2	
5	Lifting lugs	2	
6	Earthing terminals	3	
7	Bidirectional rollers	4	
8	Thermometer pocket	1	
9	Bimetal thermometer with indicator	1	
10	Oil drain valve	1	
11	Lockable oil filling plug	1	
12	Oil level indicator	1	Enables continuous oil level monitoring
13	Filling pipe with safety valve	1	Oil filling and overpressure relief
14	Pressure relief valve	1	Controlled overpressure discharge
15	Electrostatic screens	-	PV dedicated design

Optional equipment

1	DGPT2 ®
2	Anti vibration pads
3	TOGA HV transformer terminals
4	TOGA LV transformer terminals
5	EUROMOLD ® 250A
6	Integrated OLTC by Reinhausen
7	Unpainted version
8	Version with conservator

Technical description

Energeks MarkoEco2 hermetic oil transformers are designed and manufactured in accordance with European standards and applicable operating standards for MV/LV equipment. The design is based on ONAN natural oil cooling and copper windings ensuring low load losses thanks to high thermal and mechanical resistance. The equipment **meets the requirements of EN 60076, EN 50588-1 and EN 50708-1, and complies with EcoDesign (Stage II) and EU REG 548/2014 regulations.**

Short circuit parameters

Transformers with **rated power above 400 kVA are manufactured with short circuit voltage of 6% (±10%)** at rated tap position, in accordance with commonly applied technical requirements in distribution networks and design documentation for this power class.

All transformers are equipped with **regulation tappings ±3 × 2.5%**, enabling proper voltage level compensation.

Each transformer is supplied with a **complete set of equipment required for grid operation, compliant with standards applicable to MV/LV transformers used in distribution, industrial and commercial networks.**

Zabezpieczenie antykorozyjne

All steel components of the tank, cover and external equipment are protected by a **coating system compliant with PN EN ISO 12944, corrosion category C3H**, intended for operation in environments with increased corrosive aggressiveness.

The protection system includes a primer layer and a top coat, each in a different colour, in accordance with dual layer coating principles. The top coat is grey and resistant to insulating cooling medium, weather conditions and UV radiation.

Documentation and conformity

Each transformer is supplied with:

- catalogue data sheet, installation instructions & technical documentation
- type test reports or certified copies
- documents confirming compliance with EN 60076 1 Transformers Part 1 General requirements
- reports issued by PCA accredited bodies or bodies being signatories to EA MLA, IAF MLA or ILAC MRA agreements
- confirmation of participation of the accreditation body in international accreditation recognition agreements
- EC Declaration of Conformity confirming compliance with applicable EU directives and regulations
- warranty card defining warranty conditions and operating rules

- documentation confirming that the transformer is manufactured under a quality management system compliant with ISO 9001
- documentation confirming that the manufacturer operates an environmental management system compliant with ISO 14001

The documentation is complete and compliant with requirements applicable to MV transformers within the European Union, facilitating acceptance procedures, approvals and integration with power installations.

Applications

MarkoEco2, hermetically sealed oil immersed transformers are intended for a wide range of applications in distribution, industrial and commercial power engineering. **Technical parameters and equipment configurations meet standards applied by distribution system operators in Poland**, including PGE, Tauron, Enea and Energa Orlen, as well as other DSOs, facilitating integration with MV/LV infrastructure.

The transformers are used in:

- industrial installations and manufacturing plants supplying CNC machines, production lines and automation systems, stabilizing voltage under dynamic load changes and cooperating with UPS systems and backup power systems
- photovoltaic installations as voltage step up elements from inverters to LV or MV level, compliant with EN 50588 1, used in rooftop and ground mounted farms, also in versions with electrostatic screens for PV
- prefabricated container substations, where compact dimensions and rolling system enable easy integration with E House modules and station enclosures
- backup and emergency power supply systems cooperating with generator sets and automatic transfer systems, ensuring stability and continuity of supply for critical facilities
- commercial facilities and local distribution networks such as office buildings, shopping centres and logistics hubs, with the possibility of integration with SCADA and BMS systems